

Michael Preziosi, P.E. Director – D.O.T.S

Martin G. Rogers, P.E.

Director of Code Enforcement/D.O.T.S.

Holly Haight Assistant Director of Code Enforcement /D.O.T.S.

TO: Chris Kehoe Director of Planning

Thomas F. Wood, Esq. Town Attorney

Michael Cunningham, Esq. Deputy Town Attorney

- FROM: Holly M. Haight Asst. Director of Code Enforcement
- RE: Yeshiva Fire Inspection October 21, 2022

DATE: October 21, 2022

Gentlemen:

On October 21, 2022, I inspected all the buildings located at the Yeshiva on 141 Furnace Woods Road. Present with me was Gary Brach for the Yeshiva.

During the inspection, I found a ceiling light that was hanging in one of the dorm rooms. Repair was completed immediately.

I found the following during the rest of the inspection:

Wolowitz Building (former pool):

Fire alarm system was normal.
Fire extinguishers were all tagged appropriately and in date
All emergency and exit lighting were operational
CO detection was installed.
All dorm rooms on main level have the appropriate number of beds in each
Basement dorm rooms and bathrooms are under construction per Building Permit #20220997

Dallas Building:

Fire alarm system was normal Fire extinguishers were all tagged appropriately and in date All emergency lighting and exit lighting were operational

TOWN OF CORTLANDT DEPARTMENT OF TECHNICAL SERVICES CODE ENFORCEMENT DIVISION

Town Hall, 1 Heady Street Cortlandt Manor, NY 10567 Main #: 914-734-1010 Fax #: 914-293-0991 Town Supervisor Richard H. Becker

Town Board James F. Creighton Francis X. Farrell Cristin Jacoby Robert Mayes



Michael Preziosi, P.E. Director – D.O.T.S

Martin G. Rogers, P.E.

Director of Code Enforcement/D.O.T.S.

Holly Haight Assistant Director of Code Enforcement /D.O.T.S.

CO detection was installed.

TOWN OF CORTLANDT DEPARTMENT OF TECHNICAL SERVICES CODE ENFORCEMENT DIVISION

> Town Hall, 1 Heady Street Cortlandt Manor, NY 10567 Main #: 914-734-1010 Fax #: 914-293-0991

Town Supervisor Richard H. Becker

Town Board James F. Creighton Francis X. Farrell Cristin Jacoby Robert Mayes

Bed count was 80 (no change from 2021). All rooms had the appropriate number of beds in each. All self-closers for egress doors were operational.

Classroom/Kitchen/Dining Building:

Fire alarm system was normal Fire extinguishers were all tagged appropriately and in date All emergency lighting and exit lighting were operational CO detection was installed Classrooms were inspected and found to have no violations noted. Kitchen hood is clean, ansul system is in date, all grease catchers in place. Stoves and ovens free of grease accumulation.

Offices/Apartments:

Fire alarm system was normal Fire extinguishers were all tagged appropriately and in date All emergency lighting was operational CO detection was installed

Chalet Building:

Fire alarm system was normal Fire extinguishers were all tagged appropriately and in date All emergency lighting was operational CO detection was installed Dorm room bed count is 36 (no change from 2021). All rooms had the appropriate number of beds in each.

In summary as noted above, fire alarm systems are secure and operational in each building and are maintained by Ken Marcus of EIPS. All fire extinguishers are hung, in service and tagged appropriately. The ansul system in the kitchen is in service, and in date (last inspection August 2022). Hood is free from grease accumulation. Grease trap is maintained and was cleaned out by Pizzella on August 10, 2022. All emergency lighting and exit lights are operational.

The site is minimal compliance with the New York State Codes as of this date.

If you require anything further, please let me know.

- Cc: Martin Rogers, PE Director of Code Enforcement
 - Members of the Planning Board

Gary Brach, Yeshiva